

# Request for Quotations

	Tender	Description	Qty	Specs
1	441-24	<p>Contractor to replace a leaking tank on a supply and fix terms as per scope below and BOQ:</p> <ul style="list-style-type: none"> <li>• Clear site and prepare for concrete slab for skid tank.</li> <li>• Reinforced concrete grade 30MPa concrete slab.</li> <li>• Supply and fix steel, 6mm double wall diesel skid tank, capacity 20000litre (see attached typical skid tank drawing below)</li> <li>• Construct 230mm bund wall of face brick around skid wall. Height of bund wall to be 1000mm above ground.</li> <li>• Construct oil interceptor drainage</li> <li>• Connect skid tank to existing diesel fuel pump</li> <li>• Tank calibration, dipstick and chart</li> <li>• Testing and commissioning.</li> </ul> <p>NOTE: TANK TO CONFORM TO SAZ OR SABS STANDARDS, TO BE PAINTED WITH CORROCOTE FOR SURFACE TANKS (E.G EPOXY TAR BLACK OR ALUMINIUM)</p> <p><b>BIDDERS COMPULSORY REQUIREMENTS:</b></p> <ul style="list-style-type: none"> <li>• FACTORY VISIT</li> <li>• AT LEAST 3 TRACEABLE REFERENCES FOR SIMILAR WORKS</li> <li>• AT LEAST 20 YEARS GUARANTEE FOR THE TANK</li> <li>• CERTIFICATION FROM REGULATORY BODY (NSSA)</li> <li>• COMPULSORY SITE VISIT ON 26 APRIL 2024 AT 11:00HRS AT TELONE TOPYARD BULAWAYO</li> </ul>	<p>60sqm</p> <p>7cum</p> <p>1</p> <p>31m</p> <p>1</p> <p>1</p> <p>1</p> <p>1</p>	

Bidders with outstanding orders for any of the above items will not be considered for supply

TELONE RESERVES THE RIGHT TO INCREASE AND DECREASE QUANTITY

Please note that only bidders registered with **Procurement Regulatory Authority of Zimbabwe (PRAZ)** shall be considered.

**(Please attach Proof of PRAZ registration in the specified category)**

**Closing date for ALL Tenders: On or before 1100hrs; Thursday 02 May 2024**

**(Pricing MUST be strictly in ZWL unless requested otherwise or risk being automatically disqualified)**

Your Tender should state the price (Please state your **VAT** status), a firm delivery date Emailed to [procurement@telone.co.zw](mailto:procurement@telone.co.zw)

- **Bidders should also be compliant with the new regulations for FISCAL TAX INVOICE where necessary.**
- **Each tender should be in its own envelop, tenders should not be mixed on one quotation.**

- DRAWING OF TYPICAL SKID TANK INSTALLATION
- TO BE USED IN CONJUNCTION WITH B OF Q FOR TELONE BULAWAYO STORES

