Request for Quotations

	Tender	Description	Quan tity	Sample/Specs
1.	516-21	Supply and delivery of Office Fridges Executive desk Heaters	3 1 3	270 litres, recommended brands only Hard wood
2.	517-21	Supply and delivery of Mutton Cloth 1 kg	600	Sample available for viewing at General Stores, Epton Street.
3	518-21	For the supply and delivery of 18 000btu/h mid wall split air- conditioning unit at westgate STOCK MUST BE AVAILABLE	1	Specs attached below the table
4	519-21	For the supply and delivery of Thule 23L Subterra Backpack laptop bag for Macbook laptop	1	
5	520-21	For the supply and delivery of cellphones 1. Samsung Galaxy Note 20 ultra, mystic Bronze, 256GB dual sim	1	
		 iPhone 12 Pro Max Graphite or Pacific Blue color Samsung Galaxy Note 10 dual sim MUST BE AVAILABLE IN STOCK FOR URGENT DRIVE 	1	

Please note that **only** bidders registered with **Procurement Regulatory Authority of Zimbabwe (PRAZ) shall** be considered.

(Please attach Proof of PRAZ registration in the specified category)

Closing date for ALL Tenders: On or before 1100hrs; Wednesday 9 June 2021

Your Tender should state the price (Please state your VAT status), a firm delivery date and be placed in the tender box on the 8th Floor, South Wing, Runhare House, 107 Kwame Nkrumah Avenue, Harare; OR Emailed to procurement@telone.co.zw

Tel; 264 4 798111; 2902168; Fax 264 4 795499 Runhare House, 107 Kwame Nkrumah Avenue, Harare,





The Scope of Works Shall Include:

- Supply, installation, and commissioning of the one by 18000 BTU/h mid wall split unit
- TelOne shall provide power within 4 metres of the inside unit.
- Estimated pipe-run shall not exceed 20 metres.
- TelOne expects a product warranty of 12 months.
- The contractor is expected to perform quarterly services during the warranty period and the quoted price should be **inclusive** of these services.

The Air Conditioning Unit Technical Specifications Are Listed Below:

- The air conditioning unit shall be a cooling only model.
- The air conditioning unit shall be controlled via a wireless remote controller.
- The units shall be an energy efficient using dual DC inverter technology
- The unit shall utilise R410A refrigerant only.
- Piping for the units shall be drawn copper.
- Tel-One expects a Warranty Period of one year.
- The unit shall have a power cut auto-restart feature.
- The unit shall have a temperature display on the indoor unit.
- The unit shall have gold fins to protect the condenser coils from external damage due to the accumulation of water.

NB, Bidders to submit data sheets of their offer, failure of which shall lead to automatic disqualification